



3933 US ROUTE 11, CORTLAND, NEW YORK 13045
 Phone Number: 1-800-345-3851 Fax Number: 607-758-3648

REPORT OF TEST


Panduit Corporation
 10500 167th Street
 Orland Park, IL 60467

The products described in this Report were tested and examined by Intertek for compliance to the standards listed below. The products listed below are not part of an Intertek Verification Program. The results are provided to the client as a one time performance test and shall not be utilized to imply compliance to the standard as part of an on-going program.

Reference Intertek Report No.: 100222379CRT-001

Date: September 23, 2010

3 Connectors channel:



Component Id	Manufacturer	Description	Part number
1	Panduit	Work Area Cord	UTP6ASD5M
2	Panduit	Faceplates / Connector	CFFP12IW-2G / CJ6X88TG
3	Panduit	Consolidation Point Cable	UXJPBU15BL
4	Panduit	Horizontal Cable	PUP6ASD04
5	Panduit	Patch Panel / Connector	UICMPP24BLY / CJ6X88TG
6	Panduit	Patch Cord	UTP6ASD2M
7	Panduit	Equipment Cord	UTP6ASD3M


Conclusion:

The channel configuration, as previously described, was tested in accordance with the following standard:

ANSI/TIA-568-C.2-2009: Balanced Twisted-Pair Telecommunications Cabling and Components Standards, dated August 2009

The channel configuration was found to be in compliance with the applicable standard. The testing was performed at Intertek, located in Cortland, NY.

Reviewed and approved by:


 John Cash
 Technician
 Global Cabling Products Testing


 Antoine Pelletier
 Engineer
 Global Cabling Products Testing

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.